




Date : 2017-05-29

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	20140568/OG16	CERTIFICATE NUMBER	SP199/14
DATE OF ISSUE	26.09.2014	DATE OF ISSUE	30.09.2014
DATE OF EXPIRY	N/A	DATE OF EXPIRY	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	KZWM OGNIOPHON S.A.	NAME OF THE BRAND	KZWM OGNIOPHON S.A.
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	ul. Krakowska 83c , 34-120 Andrychów, POLAND	MODEL / NO	GS-5x B/MP
WEBSITE	www.ogniochron.eu	LOGO ON THE PRODUCT	
TEL	+48 33 875 10 70	EMAIL	biuro@ogniochron.eu



Product Details From Test Report		Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	5 kg CO ₂ portable carbon dioxide fire extinguisher, fire rating 89B, operating temperature range : -30°C to +60°C.	1 / 37; 2 / 37
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7 : 2004-01 + A1 : 2007 Portable fire extinguishers – Part 7 in conjunction with the requirements of EN 3-10:2009 Portable fire extinguishers – Part 10	1 / 37
TEST DESCRIPTION	1. Performance characteristics of the fire extinguisher	2 / 37
	2. Conformity of submitted samples with all applicable clauses EN 3	4 / 37
SPECIFICATION OF TEST SPECIMEN	Fire extinguisher type: portable carbon dioxide type Nominal charge: 5kg Propellant: CO ₂ Provided quantity: 50 samples Date of receipt: 2014-04-15	1 / 37 2 / 37
TEST RESULT (SUCH AS PASSED CRITERIA___/ COMPLIED TO___/ DURATION___/OBSERVATION___/ETC)	Performance characteristics of the fire extinguisher Class B fire rating 89B pass	2 / 37
	Operating temperature range -30°C to +60°C pass Conformity of submitted samples with all applicable clauses of EN 3-7 pass	4 / 37
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN___/TO BE INSTALLED AT___/TO BE CONNECTED WITH___/TO BE INSTALLED WITH___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN___/NOT TO BE INSTALLED AT___/ NOT TO BE INSTALLED WITH___ ETC.	End use: Fire protection in the private, public and industrial sectors. Operating instructions: Pull out safety pin Direct the nozzle to the seat of fire Squeeze the operating lever Use only on fires of fire class B Caution in electric installations Up to 1000V only. Minimum distance 1m.	2 / 37 Annex 2



Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	http://www.mpa-dresden.de	WEBSITE	http://www.mpa-dresden.de
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	DAkKS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de	ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	DAkKS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de
AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	DIN EN ISO/IEC 17065	AS PER	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY	2019-09-15	VALIDITY	a) 2019-08-10 b) 2018-09-12
REFERENCE NUMBER:	D-ZE-17819-01-00	REFERENCE NUMBER:	a) D-PL-17819-01-00 b) D-IS-17819-01-00
CERTIFICATION MARK			

(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Grzegorz Tomiak President	SIGNATURE	
EMAIL / TEL	biuro@ogniochron.eu +48 33 875 10 70	FACTORY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate KRS 0000084681			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	Grad. Eng. Bernd Ruhle	SIGNATURE	
EMAIL / TEL	b.ruhle@mpa-dresden.de + 49(0)3731 20 393-0	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)