United Arab Emirates
Ministry of interior
Civil Defense G.H.Q
Fire intentional Lab & House
Of Expertise & Training Center
Approval Committee



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

Date: 2019-02-22

CERTIFICATE OF COMPLIANCE

	This certificate of compl	iance validates	the following
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	20180959/MK24	CERTIFICATE NUMBER	SP 05/19
DATE OF ISSUE	2019/01/28	DATE OF ISSUE	2019/02/18
DATE OF EXPIRY	-	DATE OF EXPIRY	-
	Manufac	turer details	
NAME OF FACTORY/ MANUFACTURER	MOBIAK S.A.	NAME OF THE BRAND	MOBIAK S.A.
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	AKROTIRI, CHANIA, CRETE, PC73100, GREECE	MODEL / NO	MBK18-060HFC-P1A
WEBSITE	https://www.mobiak.gr/	LOGO ON THE PRODUCT	ADDBIAK® FIREFIGHTING - GASES - MEDICAL 651. 1977
TEL	+30 28210 63222	EMAIL	info@mobiak.gr

United Arab Emirates
Ministry of interior
Civil Defense G.H.Q
Fire intentional Lab & House
Of Expertise & Training Center
Approval Committee



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

	Product Details From Test Report	Reference Test Report page NO
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	Portable fire extinguisher with 6kg HFC236fa Fire rating 5A, 55B,	1-3
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 3-7:2004+A1:2007 Portable fire extinguishers – Part 7 In conjunction with the requirements of EN 3-10:2009 Portable fire extinguishers – Part 10	1
TEST DESCRIPTION	 Performance characteristics of the fire extinguisher Conformity of submitted samples with all applicable clauses of EN3 	2 - 3 5 - 6
SPECIFICATION OF TEST SPECIMEN	Fire extinguisher type: portable stored pressure type Nominal charge: $6kg$ HFC236fa Propellant: N_2 Provided quantity: 50 samples Date of receipt: $2018/06/13 \& 2018/08/30$	1-2
TEST RESULT (SUCH AS PASSED CRITERIA/ COMPLIED TO/ DURATION/OBSERVATION/ETC)	Performance characteristics of the fire extinguisher Class A fire rating achieved 5B pass Class B fire rating achieved 55B pass Operating temperature range -10°C to +60°C pass Conformity of submitted samples with all applicable clauses of EN 3-7 pass	3 5 - 32
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN	End use: Fire protection in the private, public and industrial sectors Operating instructions: Pull out safety pin Aim at the base of the fire Squeeze valve lever Avoid skin and eye contact In case of inhalation of the HFC236fa, seek medical help Suitable for use on live electrical equipment up to 1000V hold the nozzle at a minimum distance of 1m. Vessel under pressure: 15bar (20°C)	Annex 2

United Arab Emirates Ministry of interior Civil Defense G.H.Q Fire intentional Lab & House Of Expertise & Training Center **Approval Committee**



دولة الامارات العربية المتحدة وزارة الداخلية القيادة العامة للدفاع المدني لجنة اعتماد المختبرات العالمية وبيوت الخبرة ومعاهد التدريب

Laboratory and Certification body details			
NAME OF CERTIFICATION BODY	MPA Dresden GmbH	NAME OF TEST FACILITY	MPA Dresden GmbH
CERTIFICATION BODY ADDRESS / REGION (STREET/TOWN/CITY/COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany	TEST FACILITY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Fuchsmühlenweg 6F D-09599 Freiberg Germany
WEBSITE	http://www.mpa-dresden.de	WEBSITE	http://www.mpa-dresden.de
TEL	+ 49(0)3731 20 393-0	TEL	+ 49(0)3731 20 393-0
EMAIL	info@mpa-dresden.de	EMAIL	info@mpa-dresden.de
ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)	DAkkS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de	ACCREDITED BY (NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)	DAkkS Deutsche Akkreditierungsstelle GmbH http://www.dakks.de
AS PER(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)	DIN EN ISO/IEC 17065	AS PER	a) DIN EN ISO/IEC 17025 b) DIN EN ISO/IEC 17020
VALIDITY	2023-08-19	VALIDITY	a) 2019-08-10 b) 2023-08-19
REFERENCE NUMBER:	D-ZE-17819-01-00	REFERENCE NUMBER:	a) D-PL-17819-01-00 b) D-IS-17819-01-00
CERTIFICATION MARK	MPA Dresden		•

	(ENDORSEMENT) TO B	E SIGNED BY MANUFACTU	RER
NAME OF MANUFAC- TURER'S SIGNATORY	President & CEO of MOBIAK S.A. Manolis Svourakis	SIGNATURE	STANKON STANKON
EMAIL / TEL	info@mobiak.gr +30 28210 63222	FACTORY OFFICIAL SEAL	THE THE GASE WOLCAL
NOTES: I Undertake tha	t all data and information p	provided are genuine and ac	curate

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICA- TION BODY SIGNATORY	Grad. Eng. Bernd Ruhle	SIGNATURE	Thoule
EMAIL / TEL	b.ruhle@mpa-dresden.de + 49(0)3731 20 393-0	CERTIFICATION BODY OFFICIAL SEAL	Soresden Chin

ATTACHMENTS:

COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)