Product certification schedule

PZP 001 AZG





Name of schedule	Approval Certificate for portable and mobile fire extinguishers	
Type of products	Portable fire extinguisher	Mobile fire extinguisher
Applied Standards and specifications	DIN EN 3-7:2007 DIN EN 3-10:2009	DIN EN 1866-1:2007
	Verification of the suitability of the fire extinguishing media used by means of certificate or declaration of conformity by MPA Dresden GmbH	
Application	To the MPA Dresden GmbH certification body Documentation to be submitted: Full information on the applicant, manufacturer and all production facilities, complete technical documentation on the product and corresponding number of test objects Technical (pressure) evidence in accordance with Directive 2014/68/EU as a minimum	
Contractual conditions	Conclusion of a certification contract and recognition of the MPA Dresden GmbH rules of procedure for certification Where the manufacturer and production facility are different companies, contractual agreements are to be concluded between the two and these submitted to the certification body	
Sampling	Delivery by the manufacturer to the required scope	
Test	Type test and issuance of a test report by the MPA Dresden GmbH accredited testing laboratory in accordance with the above stated Standards. Test documents from other accredited testing laboratories can also be used as a basis for the MPA Dresden GmbH test report. The decision in this regard is made by the manager of the certification body.	
Initial inspection	Inspection of factory and factory production control by the MPA Dresden GmbH accredited inspection body with the aid of product-specific checklists and the compilation of an inspection report.	
Certificates	"DIN EN 3 Approval Certificate" (EN 3 – Reference to portable fire extinguishers)	"DIN EN 1866-1 Approval Certificate"
	The certificates are issued for an indefinite period. A list of the certificates will be published on the MPA Dresden GmbH website with the following information: No. of the Approval Certificate, date of issue, type designation, certificate holder, fire class	
Mark of conformity	No special certification mark will be awarded. The certificate number consists of: SP consecutive number / last two digits of the year The manufacturer receives the right to state the certificate number (approval number) on the marking label of the fire extinguishing equipment.	

Product certification schedule

PZP 001 AZG

Approval Certificate for portable and mobile fire extinguishers



Maintaining	Inspection	
	Inspection of factory and factory production control by the MPA Dresden GmbH accredited inspection body with the aid of product-specific checklists and the compilation of an inspection report.	
	Inspection frequency: at least once a year	
	Examination and evaluation of the results of the inspections	
	Alterations to the product:	
	Where alterations are made to the product, an supplement to the Approval Certificate can be issued upon application by the manufacturer. The necessity and scope of additional tests and inspection is decided by the certification body.	