

Product certification schedule

PZP 005 GSG
GS certificate for portable and wheeled fire extinguishing equipment



Name of schedule	GS certificate for portable and wheeled fire extinguishing equipment	
Type of products	Portable fire extinguishing equipment	Wheeled fire extinguishing equipment
Applied Standards and specifications	DIN EN 3-7:2007 DIN EN 3-10:2009	DIN EN 1866-1:2007
	Verification of the suitability of the fire extinguishing medium used by means of certificate or declaration of conformity by MPA Dresden GmbH	
	Legislation on the bringing of products onto the market (Product Safety Law – ProdSG) 2011-11	
	GS specification AfPS GS 2014:01 PAK "Testing and evaluation of polycyclic aromatic hydrocarbons (PAH's) with the awarding of the GS mark"	
Application	To the MPA Dresden GmbH certification centre Documentation to be submitted: Full information on the applicant, manufacturer and all production facilities, complete technical documentation on the product and corresponding number of test objects Typographical evidence in accordance with Directive 2014/68/EU as a minimum	
Contractual conditions	Conclusion of a certification contract and recognition of the MPA Dresden GmbH rules of procedure for certification Where the manufacturer and production facility are different companies, contractual agreements are to be concluded between the two and these submitted to the certification centre	
Sampling	Delivery by the manufacturer to the required scope	
Test	Type test and issuance of a test report by the MPA Dresden GmbH recognised test centre in accordance with the above stated Standards and specifications. Test documents from other recognised test centres can also be used as a basis for the MPA Dresden GmbH test report. The decision in this regard is made by the manager of the certification centre.	
Initial inspection	Inspection of the works and works in-house production control by the MPA Dresden GmbH accredited inspection centre with the aid of product-specific checklists and the compilation of an inspection report.	
Certificates	GS certificate	
	Maximum validity 5 years, can be extended on application	
	A list of the certificates will be published on the MPA Dresden GmbH website with the following information: Owner of the GS mark, type designation, no. of the GS mark, valid until	

Product certification schedule

PZP 005 GSG
GS certificate for portable and wheeled fire extinguishing equipment



Mark of conformity	<p>GS logo with integrated MPA Dresden ID mark</p> <p>The certificate number consists of: SP consecutive number / last two digits of the year</p> <p>The manufacturer receives the right to illustrate the mark on the labelling image of the fire extinguishing equipment. See rules of procedure for certification for further regulations on the application.</p>
Perpetuation	<p>Inspection</p> <p>Inspection of the works and works in-house production control by the MPA Dresden GmbH accredited inspection centre with the aid of product-specific checklists and the compilation of an inspection report.</p> <p>Inspection frequency: at least once a year</p> <hr/> <p>Examination and evaluation of the results of the inspections</p> <hr/> <p>Alterations to the product:</p> <p>Where alterations are made to the product, an amendment to the GS certificate can be issued upon application by the manufacturer.</p> <p>The necessity and scope of additional tests and inspection is decided by the certification centre.</p>