

Product certification schedule**PZP 006 GSD**
GS certification of fire extinguishing sprays

Name of schedule	GS certification of fire extinguishing sprays
Type of products	Fire extinguishing spray for once-only use
Applied Standards and Specifications	EN 16856:2020-04
	Verification of the suitability of the fire extinguishing medium used by means of certificate or declaration of conformity by MPA Dresden GmbH
	Legislation on the bringing of products onto the market (Product Safety Law – ProdSG) 2021-07
	EK5/TA7 29-11:2021 Principles for the testing and Certification of Fire Extinguishing Sprays dated 29.11.2021
	GS specification AfPS GS 2019:01 PAK “Testing and evaluation of polycyclic aromatic hydrocarbons (PAH’s) with the awarding of the GS mark”
Application	To the MPA Dresden GmbH certification centre Documentation to be submitted: Full information on the applicant, manufacturer and all production facilities, complete technical documentation on the product and corresponding number of test objects Verification of adherence to the Directive 75/324/EEC
Contractual conditions	Conclusion of a certification contract and recognition of the MPA Dresden GmbH rules of procedure for certification Where the manufacturer and production facility are different companies, contractual agreements are to be concluded between the two and these submitted to the certification centre
Sampling	Delivery by the manufacturer to the required scope
Test	Type test and issuance of a test report by the MPA Dresden GmbH recognised test centre in accordance with the above stated Standards and specifications. Test documents from other recognised test centres can also be used as a basis for the MPA Dresden GmbH test report. The decision in this regard is made by the manager of the certification centre.
Initial inspection	Inspection of the works and works in-house production control by the MPA Dresden GmbH accredited inspection centre with the aid of product-specific checklists and the compilation of inspection report.
Certificates	GS certificate
	Maximum validity 5 years, can be extended on application
	A list of the certificates will be published on the MPA Dresden GmbH website with the following information: Owner of the GS mark, type designation, no. of the GS mark, valid until

Product certification schedule

PZP 006 GSD
GS certification of fire extinguishing sprays



Mark of conformity	<p>GS logo with integrated MPA Dresden ID mark</p> <p>The certificate number consists of: GS consecutive number / last two digits of the year</p> <p>The manufacturer receives the right to illustrate the mark on the labelling image of the fire extinguishing equipment. See rules of procedure for certification for further regulations on the application.</p>
Perpetuation	<p>Inspection</p> <p>Inspection of the works and works in-house production control by the MPA Dresden GmbH accredited inspection centre with the aid of product-specific checklists and the compilation of an inspection report.</p> <p>Inspection frequency: at least once a year</p>
	<p>Examination and evaluation of the results of the inspections</p>
	<p>Alterations to the product:</p> <p>Where alterations are made to the product, an amendment to the GS certificate can be issued upon application by the manufacturer.</p> <p>The necessity and scope of additional tests and inspection is decided by the certification centre.</p>